

Kidde Engineered Fire Suppression System

Designed for use with 3M™ Novec™ 1230 Fire Protection Fluid



Effective: June 2015

3M™ Novec™ 1230 Fire Protection Fluid

K-45-1900

FEATURES

- **People Safe at Concentration Levels Required to Extinguish Fire**
- **Zero Ozone Depletion Potential**
- **Atmospheric Lifetime of Five Days**
- **Colorless, with Low Odor and No Particulate or Oily Residue Allowing for Minimal Business Disruption After a Discharge**
- **Electrically Non-Conductive**
- **Space Saving; Quantity of Agent Needed to Extinguish Fires Typically Required Minimal Cylinders, thus Minimal Space Required**
- **UL Listed, ULC Listed, and FM Approved for use with Novec 1230 Systems**

EXTINGUISHING AGENT

3M™ Novec™ 1230 Fire Protection Fluid (Novec 1230) is a fluorinated ketone (FK-5-1-12) Dodecafluoro-2-methylpentan-3-one) compound of carbon, fluorine and oxygen (CF₃CF₂C(O)CF(CF₃)₂). It is colorless, electrically non-conductive and has a low odor. It suppresses fire primarily by physical mechanisms due to its relatively high heat capacity with minimal effect on the available oxygen. This allows people to see and breathe, permitting them to leave the fire area safely.

Novec 1230 fluid is acceptable for use in occupied spaces when used in accordance with the United States Environmental Protection Agency (EPA) Significant New Alternatives Policy (SNAP) program rules.

Although Novec 1230 fluid is considered non-toxic to humans in concentrations necessary to extinguish most fires, certain safety considerations should be observed when applying and handling the agent. The discharge of Novec 1230 fluid may create a hazard to people from the decomposition products which result when the agent is exposed to fire or other hot surfaces. Exposure to the agent is generally of less concern than is exposure to the decomposition products. Unnecessary exposure to the agent or the decomposition products should be avoided.

TOXICITY

Unnecessary exposure to clean agents is to be avoided in accordance with the requirements of NFPA-2001. As such, upon operation of a system pre-discharge alarm, all personnel should immediately exit the protected space. In no case shall personnel remain in a room in which there is a fire. In the very unlikely instance where a clean agent system should discharge unexpectedly into an occupied room, all personnel should proceed in a calm and orderly manner to an exit and leave the room.

Novec 1230 fluid has been evaluated for cardiac sensitization in accordance with test protocols approved by the United States Environmental Protection Agency (U.S. EPA). The EPA's SNAP Program classifies Novec 1230

fluid as acceptable for use as a total flooding agent in occupied spaces with specific limitations. Refer to the SNAP program rules or NFPA 2001 for more information. Novec 1230 fluid has been judged acceptable by the U.S. EPA for use in occupied spaces when used in accordance with the guidance of NFPA 2001. In accordance with NFPA 2001, Novec 1230 fluid designed for use with agent vapor concentrations up to ten volume percent in air are permitted. See NFPA 2001, Sect. 1-6, *Safety*.

Although Novec 1230 fluid has negligible toxicity in concentrations needed to suppress most fires, certain safety considerations must be observed when applying and handling the agent. For example, Novec 1230 fluid is a liquid at room temperature and has been superpressurized with dry nitrogen. Upon release to atmospheric pressure (e.g., from nozzles) the liquid flash evaporates at a low temperature. Thus, nozzles must be located to avoid direct impingement on personnel.

DECOMPOSITION

When Novec 1230 fluid is exposed to high temperatures, such as what may be expected in a flame front, hazardous products of thermal decomposition (halogen acids) are produced. If the Novec 1230 fluid is discharged in 10 seconds or less, flames will be extinguished rapidly and the amount of by-products produced will be minimal.

CLEANLINESS

Novec 1230 fluid is clean and leaves no residue, thereby eliminating costly after-fire clean-up and keeping expensive downtime to a minimum. Most materials such as steel, stainless steel, aluminum, brass and other metals as well as plastics, rubber and electronic components are unaffected by exposure to Novec 1230 fluid.

APPROVALS

Novec 1230 fluid complies with the NFPA Standard 2001, Standard for Clean Agent Fire Extinguishing Systems, EPA SNAP Program, (Significant New Alternate Policy), Underwriters Laboratories, Inc. (UL) FM Approvals (FM).

USE

Kidde Engineered Fire Suppression Systems Designed for use with 3M™ Novec™ 1230 Fire Protection Fluid are designed to extinguish fires in specific hazards or equipment located where an electrically non-conductive agent is required, where agent cleanup creates a problem, where extinguishing capability with low weight is a factor and where the hazard is normally occupied by personnel. Novec 1230 fluid is an acceptable alternative to Halon and is approved by the EPA and NFPA for use in fire suppression systems.

Table 1: Novec 1230 Fluid Physical Properties

Chemical Formula	CF ₃ CF ₂ C(O)CF(CF ₃) ₂
Molecular Weight	316.04
Freezing Point	-162.4°F (-108°C)
Boiling Point at 1 Atm.	120.6°F (49.2°C)
Critical Temperature	335.6°F (168.7°C)
Critical Density	39.91 lb./ft. ³ (639.1 kg/m ³)
Critical Pressure	270.44 PSIA (1865 kPA)
Critical Volume	0.0251 ft. ³ /lbm (494.5 cc/mole)
Ozone Depletion Potential	0
Global Warming Potential	1

Table 2: Novec 1230 Fluid Toxicity Properties

Novec 1230 Fluid Toxicity Properties	
NOAEL (No Observable Adverse Effect Level)	10.0%
LOAEL (Lowest Observable Adverse Effect Level)	10.0% >

Table 3: Novec 1230 Fluid Design Concentrations

Fuel	Design Concentration, % v/v
1-Butane	6.37
1-Propanol	7.02
2,2,4-trimethylpentane	6.11
2-butoxyethanol	6.76
Acetone	5.59
Acetonitrile	4.20
Commercial Heptane	5.72
Commercial Hexanes	5.59
Cyclohexane	5.85
Cyclopentanone	5.98
Denatured Alcohol (92.2% EtOH, 4.6% IPA, and 3.1% MeOH)	6.89
Diesel Fuel	4.42
Diethyl Ether	6.37
Ethanol	7.15
Ethyl Acetate	6.11
Gasoline-87 oct. unleaded	5.85
Hexene	5.98
Isooctane	6.11
Isopropanol Alcohol	6.37
Methane	7.28
Methanol	8.45
Methyl Ethyl Ketone	5.85
Methyl Isobutyl Ketone	5.72
Methyl Tert Butyl Ether	5.95
n-Heptane	5.85
n-Pentane	6.11
Octane	5.72
Propane	7.54
Pyrrolidine	6.11

Table 3: Novec 1230 Fluid Design Concentrations (Continued)

Fuel	Design Concentration, % v/v
Technical Heptane	5.59
Tetrahydrofuran	6.50
Toluene	4.55
Transformer Oil	5.85

- Minimum Design Concentration for Class A and de-energized Class C Fires = 4.2%
- Design concentrations for Class B Fire are shown in the above table and include a 30% safety factor from the minimum extinguishing concentration.

Kidde is a registered trademark of Kidde-Fenwal, Inc.
3M and Novec are trademarks of 3M.
All other trademarks are property of their respective owners.

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, INC.



400 Main Street
Ashland, MA 01721
Tel.: 508-881-2000
Fax: 508-881-8920
www.kiddefiresystems.com